



COMPRESSED GAS SAFETY



Store > Separate > Secure > Inspect > Close



- **Store** cylinders in cool, well-ventilated, fire-resistant areas in compliance with local, state and federal regulations.
- **Separate** flammable gases from oxidizer gases.
- **Secure** cylinders vertically with restraints, maximum two in one strap/chain. Do not roll or drop cylinders.
- **Inspect** cylinders for leaks and check support restraints regularly.
- **Close** valves and tighten caps when not in use.

Questions/Comments? Contact the Division of Occupational Health and Safety's Oxygen Monitoring Program Manager at (301) 3496-3353 or visit <https://go.usa.gov/xEGGg>.

